



The joists must have the bottom  
flange retained by 1x3 SPF#3/Stud  
or resilient channels at 16" c/c

CANTILEVERED JOIST

DETAIL No.8P